

WORK ENVIRONMENT MONITORING DATA

Sl. No.	Date	Location	Ammonia (NH ₃) ppm	Carbon Monoxide (CO) ppm
1	13-03-17	Fire & Safety Control Room	0.1	<1
2	13-03-17	OHC	0.1	<1
3	13-03-17	Control Room (Ammonia & Urea 1)	0.1	<1
4	13-03-17	Ammonia 1 (02 Area)	0.2	<1
5	13-03-17	Ammonia 1 (03 Area) Field Cabin	0.2	<1
6	13-03-17	Ammonia 1 (04 Area) Acoustic Room	0.6	<1
7	13-03-17	Ammonia 1 (05 Area) Field Cabin	0.4	<1
8	13-03-17	Field Cabin Amm 1 (Mech. Maint.)	0.2	<1
9	13-03-17	Field Cabin (Urea 1)	0.2	<1
10	13-03-17	Field Cabin Urea 1 (Mech. Maint.)	0.2	<1
11	14-03-17	Control Room (GT-C)	0.1	<1
12	14-03-17	Control Room (Ammonia & Urea 2)	0.2	<1
13	14-03-17	Ammonia 2 (02 Area)	0.2	<1
14	14-03-17	Ammonia 2 (03 Area) Field Cabin	0.2	<1
15	14-03-17	Ammonia 2 (04 Area) Acoustic Room	0.3	<1
16	14-03-17	Ammonia 2 (05 Area) Field Cabin	0.4	<1
17	14-03-17	Field Cabin Amm 2 (Mech. Maint.)	0.2	<1
18	14-03-17	Cooling Towers 2 Field Cabin	0.2	<1
19	15-03-17	Field Cabin (Urea 2)	0.2	<1
20	15-03-17	Field Cabin Urea 2 (Mech. Maint.)	0.1	<1
21	15-03-17	Loading Area (Bagging plant)	0.8	<1
22	15-03-17	Boilers Field Cabin	0.1	<1
23	15-03-17	Control Room (Boilers)	0.1	<1
24	15-03-17	Control Room (Ammonia Storage)	0.2	<1
25	15-03-17	Control Room (Cooling Towers 1)	0.2	<1
26	15-03-17	Security Gate	0.1	<1
27	15-03-17	Distribution Office at Security Gate	0.1	<1